

# Warning



## Maximum loading of earth leakage and circuit protection devices.

### **Note:**

- The maximum number of ballasts connected to earth leakage circuit protection devices shall not be greater than 40 units for fixed output and 32 units all others or “that as recommended by the protective device supplier/manufacturer whichever is the smaller number”.
- The maximum loading of automatic circuit breakers shall not be greater than those shown in the table supplied by the ballast manufacture or “that as recommended by the protective device supplier/manufacturer whichever is the smaller number”.